



A P P R O V A L S ®

Certificate of Conformity

Certificate No.: SAA-200413-EA

Certificate Holder: Zhejiang Benyi Electrical Co., Ltd.
Wenzhou Bridge Industrial Zone,
Beibaixiang, Yueqing,
Zhejiang 325603
P.R. China

Regulatory Definition: DC Isolator
Product Description: DC Switch-disconnector
Trade Name: ZJBENY
Model No.: BH-250
Markings: Number of Pole: 2/3/4P;
Ui=1500V; Uimp=12kV; -40°C to +85°C; No polarity
DC-PV2: Ue=1000/1200/1500V DC;
Ie=80/100/125/160/200/250A (3P);
DC-PV2: Ue=1000V DC;
Ie=80/100/125/160/200/250A (2P/4P);
Icw=8kA, 1s; Icm=10kA, Ith=250A,
Ithe=250A, Ithe solar at 60°C =250A
IP20 (without enclosure),
IP66NW (with dedicated individual enclosure)

Standard: AS 60947.3:2018
AS/NZS IEC 60947.1:2015

Conditions: Nil

Approval Mark: RCM and SAA-200413-EA

Date First Registered: 19 March 2020
Date of Expiry: 19 March 2025

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



Issued: 19-03-20 200413/1

www.jas-anz.org/register